

0359-CPR-00687

Intertek

Product(s): **Wireless fire points**
(refer to attached appendix for details and conditions)

placed on the market
under the name or trade
mark of:

Ramtech Electronics Limited
Abbeyfield House, Abbeyfield Road, Nottingham, NG7 2SZ

and produced in the
manufacturing plant(s):

SMS Electronics Ltd
Technology Drive, Nottingham, Nottinghamshire, NG9 1AD. UK

Intended use: Fire Safety

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN54-3:2001+A1:2002+A2:2006

EN54-11:2001+A1:2005

EN54-25:2008+AC:2012

under system 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

This certificate was first issued on **16th May 2018** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Notified Body
0359

Intertek Testing & Certification Limited
Cleeve Road, Leatherhead
Surrey, KT22 7SB
Tel: +44 (0)1372 370900
Fax: +44 (0)1372 370977
E-mail: cpd.uk@intertek.com

Nick Jones
Certification Officer

WA Jones

Date 16-May-2018
Issue 1

www.intertek.com

Registered No 3272281 Academy Place, 1-9 Brook Street, Brentwood, Essex,
CM14 5NQ, United Kingdom

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Certificate of Constancy of Performance

0359-CPR-00687



Appendix to Certificate of Constancy of Performance 0359-CPR-00687

The details and condition of use for the Wireless fire points, placed on the market by:

Ramtech Electronics Limited

Abbeyfield House, Abbeyfield Road, Nottingham, NG7 2SZ

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

Products compliant with EN54-3:2001+A1:2002+A2:2006, EN54-11:2001+A1:2005 and EN54-25:2008+AC:2012:

Model	Manufacturing Location	Description
W3-FPT-CSS-N	SMSELUK.01	Wireless Manual call point / sounder / beacon
W3-FPT-CSS-R-A*	SMSELUK.01	Wireless Manual call point / sounder / beacon
W3-FPT-CSS-R-B	SMSELUK.01	Wireless Manual call point / sounder / beacon
W3-FPT-CSS-R-C	SMSELUK.01	Wireless Manual call point / sounder / beacon
W3-FPT-CSS-R-D	SMSELUK.01	Wireless Manual call point / sounder / beacon
W3-FPT-CSS-R-E	SMSELUK.01	Wireless Manual call point / sounder / beacon
W3-FPT-SRO-N	SMSELUK.01	Wireless Manual call point / sounder
W3-FPT-SRO-R-A*	SMSELUK.01	Wireless Manual call point / sounder
W3-FPT-SRO-R-B	SMSELUK.01	Wireless Manual call point / sounder
W3-FPT-SRO-R-C	SMSELUK.01	Wireless Manual call point / sounder
W3-FPT-SRO-R-D	SMSELUK.01	Wireless Manual call point / sounder
W3-FPT-SRO-R-E	SMSELUK.01	Wireless Manual call point / sounder

*Note the suffix letter A, B, C, D and E above relates to the default tone of the unit as identified in the Approved Settings table below;

Approved settings:

Tone type	Tone No.	Suffix	Code	Description
-	2	-D	10000x11	800 Hz to 950 Hz swept at 9 Hz
English	6	-A	10100x11	800 Hz to 970 Hz swept at 1 Hz
-	19	-C	01001x11	500 Hz rising to 1200 Hz over 3.5 sec, silence for 0.5 sec
German	20	-B	11001x11	1200 Hz falling to 500 Hz over 1 S, silence for 10 ms
French	21	-E	00101x11	554 Hz for 100 ms, 440 Hz for 400 ms

Conditions of use:

Suitable for indoor and outdoor applications.

Intertek Testing & Certification Limited, Cleeve Road, Leatherhead, Surrey, KT22 7SB
Tel: + 44 (0)1372 370900, Fax: +44 (0)1372 370977, E-mail: cpd.uk@intertek.com

0359-CPR-00687
Issue 1

www.intertek.com

Registered No 3272281 Academy Place, 1-9 Brook Street, Brentwood, Essex,
CM14 5NQ, United Kingdom

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Certificate of Constancy of Performance

0359-CPR-00687



General Notes:

1. Evaluated under Intertek project numbers 102821745, 101387012 and 103124579.
2. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.
3. Devices that do not derive their power by means of a physical electrical connection are outside the scope of EN54-3:2001+A1:2002+A2:2006 and EN54-23:2010, however, the manufacturer has voluntarily requested testing and compliance to EN54-3:2001+A1:2002+A2:2006.

Intertek Testing & Certification Limited, Cleeve Road, Leatherhead, Surrey, KT22 7SB
Tel: + 44 (0)1372 370900, Fax: +44 (0)1372 370977, E-mail: cpd.uk@intertek.com

0359-CPR-00687
Issue 1

www.intertek.com

Registered No 3272281 Academy Place, 1-9 Brook Street, Brentwood, Essex,
CM14 5NQ, United Kingdom

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.